

BIDS AND AWARDS COMMITTEE

BID BULLETIN NO. 1

This Bid Bulletin is issued to amend/clarify items in the Bidding Documents for the **Supply, Delivery, and Installation of 300kWp Solar Panel System at the SEC Headquarters**, under **Competitive Bidding No. 2025-26**.

A. AMENDMENTS

REFERENCE	SPECIFICATIONS	AMENDMENT
Section III. Bid Data Sheet Page 44	ITB Clause 22.2(b) For MEARB as award criterion (15% for the price, 85% for quality), the date and time of bid opening of the financial proposals is 29 August 2025, 10:00AM.	For MEARB as award criterion (15% for the price, 85% for quality), the date and time of bid opening of the financial proposals is 29 August 2025, 10:00AM. The minimum quality score for the quality proposal shall be 75%. In evaluating the financial proposals, the lowest bid shall automatically receive 100 pts. For the succeeding proposals, the following formula shall be used: Financial Score = 100 x Lowest Bid/Bid Under Consideration
Section III. Bid Data Sheet Page 45	- additional -	ITB Clause 18 Each Bidder shall submit one (1) originally signed certified true copy of the original documents and electronic copy of first and second components of bids shall be submitted upon instructions of the BAC thru the BAC Secretariat at any time after the opening of bids. Bidders must arrange each bid document into sections with tabs properly labeled separating each document according to the provided checklist.
Section V. Special Conditions of Contract Page 64	- additional -	SCC Clause 11 Payment shall be made based on the schedule of deliverables/ timeline of milestones as indicated in the Terms of Reference (Section VII. Technical Specifications and after issuance of the Certificate of Completion by the End User Department and submission of Certificate of No-Derogatory Information of the Supplier. For the final payment and settlement of contracts,

		the following will be required from supplier: • Tax clearance certificate for Final settlement of Government contracts (TCFG) • Certification of collectible Final payment (CCFP)
Section VII. Technical Specifications Page 72	- additional -	ON-GRID, Three (3) phase (480 Volt), HYBRID INVERTER Inverter Power Output = 50kW

B. CLARIFICATIONS

REFERENCE	QUERIES	RESPONSES
Section VII. Technical Specifications Page 68-79	1. Are there no specifications for batteries?	None, because our requirements are for on-grid.
	2. The rated voltage for photovoltaic wire available in the market is 1.5kV.	The requirements in the technical specifications are the minimum, so bidders may offer more than the requirement stated.
	3. Is the application for a DER permit from MERALCO included in the timeline for deliverables?	Yes, and application is enough. The Procuring Entity understands that the issuance of such permit might take some time and thus proof of application is enough.
	4. Please confirm if there will be a combination of works as stated under item number 3 of milestone deliverables?	Yes, part of the deck is roof and part is concrete. Bidders are required to conduct an ocular inspection on the area for inspection, verification and overall project assessment, as indicated in the terms of reference.
	5. Will the SEC be looking for specific data in the shading analysis?	No specific data is required. Only a standard shading analysis is expected.
	6. Are there no specifications for the rapid shutdown system under Balance of System Components?	The specifications of the item to be offered should be included in the proposal, for consideration of the Procuring Entity.

Provisions in the bidding documents that are in conflict with this Bulletin are deemed revised/amended. For guidance and information of all concerned.

15 August 2025

For the Bids and Awards Committee:

ARMANDO A. PAN, JR.
Chairman