

**BIDS AND AWARDS COMMITTEE
GOODS (IT) AND CONSULTING SERVICES**

BID BULLETIN NO. 1

This Bid Bulletin is issued to amend/clarify items in the Bidding Documents for the **SUPPLY, DELIVERY, INSTALLATION, CONFIGURATION, COMMISSIONING AND TESTING OF CYBERSECURITY OPERATIONS CENTER FACILITY (CSOC), COMPETITIVE BIDDING NO. 2026-04.**

A. AMENDMENT/S

Reference	Amendment
Section VII. Technical Specifications Page 76 4. Floor works 1. Demolition of existing Homogeneous Floor Tiles. 2. Chipping of existing tile adhesive. 3. xxx	4. Floor works 1. Demolition of existing Homogeneous Floor Tiles. 2. Chipping of existing tile adhesive. 3. xxx

B. CLARIFICATIONS

Requirements	Bidder's Clarification	Response
Section VII. Technical Specifications 5. SITE INSPECTION AND SURVEY REQUIREMENT 5. The prospective bidder shall conduct a mandatory site inspection and technical survey of the Procuring Entity's facilities. The purpose of the site inspection is to enable bidders to: 1. xxx 2. Verify technical requirements and constraints; and 3. Ensure accuracy and completeness of their proposed solution, work plan, and cost estimates	Kindly confirm which of the following electrical tapping point specifications will be applicable for the project: 480V, 3-phase 230V, 3-phase Wye 230V, 3-phase Delta 230V, Single Phase 380V, 3-phase Delta 380V, 3-phase Wye Requesting also a copy of Single Line Diagram showing the electrical tapping points.	480V, 3-phase 230V The Single Line Diagram showing the electrical tapping points will be provided to the winning bidder upon issuance of the Notice of Award.

Section VII. Technical Specifications 4. Floor works 4. Demolition of existing Homogeneous Floor Tiles. 5. Chipping of existing tile adhesive. 6. xxx	Is this necessary? Demolition of existing Homogeneous Floor Tiles. Can you please advise if this is included in the SOW? Chipping of existing tile adhesive. Supply and Installation of Milliken Carpet.	Please refer to the amendment page.
Section VII. Technical Specifications 16. TERMS OF PAYMENT 1. Payment shall be processed after the issuance of the Certificate of Acceptance, in accordance with the government's accounting, budgeting, and auditing rules and regulations. Please note that the corresponding bank transfer fee, if any, shall be to the vendor's account. 2. An advance Payment may be requested by the Vendor pursuant to Section 71.1.5 (c) of the New Government Procurement Act (RA No. 12009) and its implementing Rules and Regulations (IRR).	What documents/attachments are required to be submitted for the request of billing, particularly the advance payment, Are there any additional procedures required by the procuring entity?	Upon submission of a written request and an irrevocable Letter of Credit or bank guarantee issued by a local bank (Please refer to Section 71.1.5(c) of RA No. 12009)
Section VII. Technical Specifications One (1) Set of Branded High-End Desktop Computer Green specifications: Compliant with the ENERGY STAR and TCO	Request to relax requirement from of ENERGY STAR and TCO to ENERGY STAR "or" TCO	The requirement is retained.
Section VII. Technical Specifications	To ensure the proper provision of supplementary support and setup required to connect the CSOC Facility to the SEC's Data Center Facility, as well as to other electrical and utility systems, the following components are indicated for installation (but not limited to): Rough-ins and cabling One (1) unit of a 24-port Network Distribution Switch In this regard, we would like to seek further details on the specific requirements for the distribution switch, particularly:	

	- What are the required port specifications (e.g., 1G, 10G, or higher)? - What uplink interfaces are expected (e.g., SFP, SFP+, QSFP, and corresponding speeds)? - What downlink port types and quantities are needed for end-device connectivity? - Is Power over Ethernet (PoE/PoE+/UPOE) required for connected devices? If so, what is the expected power budget? - Is a redundant power supply required for high availability? - Are there any specific features required (e.g., Layer 3 capabilities, VLAN support, stacking, or security features)?	1G Ethernet port RJ 45 Cat 6e cable No POE required No, a redundant power supply is not required. at least layer 2
	Provisioning of at least eight (8) convenience electrical power outlets – where would you tap or get the electrical from? Which floor and room?	The electrical panel board is located on the 4th floor. Further details will be provided to the winning bidder during the kick-off meeting.
	Are there any spare breakers for 8 convenience outlets? May we request for a schedule of load and as-built plan of existing electrical of the proposed command center.	Yes, a spare breaker may be provided. However, the winning bidder may opt to provide their own breaker for the convenience outlets. The documents will be provided to the winning bidder upon issuance of the Notice of Award.

Provisions in the bidding documents that are in conflict with this Bulletin are deemed revised/amended.

For guidance and information of all concerned.

31 March 2026

OLIVER O. LEONARDO
Chairman, Bids and Awards Committee
for Goods (IT) and Consulting Services
/mrs